

## Mg ion pumping effect during $^{24}\text{Mg}^{8+}$ ion beam production at the Hyper-ECR ion source

H. Muto,<sup>\*1</sup> M. Kase,<sup>\*1</sup> K. Kobayashi,<sup>\*2</sup> M. Nishimura,<sup>\*2</sup> S. Kubono,<sup>\*1</sup>  
Y. Ohshiro,<sup>\*3</sup> Y. Kotaka,<sup>\*3</sup> H. Yamaguchi,<sup>\*3</sup> Y. Sakemi,<sup>\*3</sup> and S. Shimoura<sup>\*3</sup>

A grating monochromator with a photomultiplier has been used for beam tuning at the Center for Nuclear Study Hyper-Electron Cyclotron Resonance (ECR) ion source.<sup>1,2)</sup> The Hyper-ECR ion source has been successfully used as an injector of the multi-charged ion beams of high intensity for the RIKEN AVF cyclotron.<sup>3)</sup>  $^{24}\text{Mg}^{8+}$  ions have been produced in the 14.2-GHz Hyper-ECR ion source. At the beginning of the chamber baking an RF power of 100 W was fed to the residual gas of the plasma chamber. The extraction voltage was set to 10 kV. Then the vacuum gauge reading rapidly dropped to less than  $10^{-4}$  Pa from the order of  $10^{-5}$  Pa and a breakdown of the high-voltage power supply occurred because of the huge drain current. A few hours later the extraction voltage was recovered and the vacuum gauge reading was restored to the order of  $10^{-5}$  Pa. The RF power was gradually increased to 600 W until a good vacuum condition ( $1\sim 5 \times 10^{-5}$  Pa) and low drain current of less than 2 mA were obtained. After baking the plasma chamber an MgO rod was gradually inserted into the chamber without excessive heat. The RF power ranges from 500 to 600 W for  $^{24}\text{Mg}^{8+}$  ion production. A grating monochromator (JASCO CT-25C) and a photomultiplier (Photosensor module H11462-031, Hamamatsu Photonics) were used for light intensity observation during chamber baking and beam operation.<sup>3)</sup> The wavelengths of the observed lines were determined in accordance with the NIST Atomic Spectra Database.<sup>4)</sup> Figure 1 shows the optical line spectrum of the Hyper-ECR ion source under plasma chamber baking. This spectrum was taken three hours from baking start. The vacuum gauge reading was  $5.7 \times 10^{-5}$  Pa. The drain current was 12 mA. The RF power was 100 W. In this figure most of the peaks were from Fe I and Fe II. The relative intensities of those Fe I and Fe II peaks are quite high. Figure 2 shows an optical line spectrum of the ECR plasma during  $^{24}\text{Mg}^{8+}$  ion beam tuning. The vacuum gauge reading was  $1.7 \times 10^{-5}$  Pa. The drain current was 1.8 mA. The RF power was 611 W. The line intensities of Fe I and Fe II almost decreased to zero and Mg line intensities appeared. Especially, the Mg VIII line spectrum ( $\lambda=279.64$  nm) was clearly obtained to identify the existence of  $^{24}\text{Mg}^{8+}$  ions in the ECR plasma. The ion source was tuned for the production of the  $^{24}\text{Mg}^{8+}$  ions. The  $\text{H}^+$  ions were also reduced during  $^{24}\text{Mg}^{8+}$  ion beam operation. From these results the ion pumping effect of Mg ions was visually demonstrated by the optical grating monochromator with a photomultiplier.




Figure 1. Light intensity spectrum of the residual gas ions during baking for three hours.




Figure 2. Optical line spectrum during  $^{24}\text{Mg}^{8+}$  ion beam tuning.

### References

- 1) H. Muto et al., Rev. Sci. Instrum. **84**, 073304 (2013).
- 2) H. Muto et al., Rev. Sci. Instrum. **85**, 02A905 (2014).
- 3) H. Muto et al., Physics Procedia **66**, 140 (2015).
- 4) [www.nist.gov/pml/data/asd.cfm](http://www.nist.gov/pml/data/asd.cfm) for NIST atomic spectrum data base.

<sup>\*1</sup> RIKEN Nishina Center

<sup>\*2</sup> Sumitomo Accelerator Service (SAS)

<sup>\*3</sup> CNS, University of Tokyo